PROFORMA REGARDING SAFE DRINKING WATER CERTIFICATE

NO WOTHLY (RK/184

Date: 13 9 29

It is certified that an inspection team headed by AMIT PRASAD BADOLA

(Sampling Assistan)Name of Officers with designation) from Uttarakhand Jal Sansthan rishikesh Name of Department/Office) inspected the

SHRI GURU RAM RAI PUBLIC SCHOOL RISHIKESH (Name & Address of the School) on 11/09/2021 and found that the

SHRI GURU RAM RAI PUBLIC SCHOOL RISHIKESH

(Name of school) has safe drinking

water facilities for the students and members of staff of the institution in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 13/9 Jery Come Year

Authorzed Signatory
SDWQTML, Rishikesh
Signature with Seal.

Name: Parmod Harwal Designation: Lob Inland

To Principal

SHRI GURU RAM RAI PUBLIC SCHOOL RISHIKESH

(Name & Address of the Institution)



जल परीक्षण (उपखण्ड)प्रयोगशाला,उत्तराखण्ड जल संस्थान,ऋषिकेश।

Email-ujslabrishikesh@gmail.com

Ref:-WQTML/rishikesh/SGRR 184

Date: 13/09/2021

Sample received From: SHRI GURU RAM RAI PUBLIC SCHOOL Rishikesh (School Aff No 3530172)

Sample received Date :- 11-09-2021 2.45pm

Sample Analysis Date :- 13-09-2021

Details Of the Sample: Submersible Sample (Sample Number 184)

Type Of the Analysis: Physico, Chemical & Bacteriological Analysis.

| Parameter | | Quality Criteria Of Drinking Water ISI(IS:10500) | | Concentration |
|-----------|-----------------------------|--|-------------------|--------------------------|
| | | Desirable Limit | Permissible Limit | No. Of Samples Result |
| S.N. | Physico & Chemical Test | | | |
| 01 | Odour | Agreeble | Agreeble | Agreeble |
| 02 | Taste | Agreeble . | Agreeble | Agreeble |
| 03 | рН | 6.5-8.5 | No Relax | 7.01 |
| 04 | Turbidity,NTU | 1 | 5 | 2.38 |
| 05 | Total Hardness,mg/l | 300 | 600 | 185 |
| 06 | Calcium mg/l | 75 | 200 | 38 |
| 07 | Alkalinity mg/l | 200 | 600 | 180 |
| 08 | Total Dissolved Solids mg/l | 500 | 2000 | 480 |
| 09 | Residual Free Chlorine mg/l | 0.2 | 1 | 0 |
| | Chloride mg/l | 250 | 1000 | 29 |
| 10 | Magnesium mg/I | ; 30 | 100 | . 36 |
| | Bactriological Test | | | · |
| 12 | E-Coli (MPN/100ml) | Absent | Absent | Absent |
| 13 | TotalColiform(MPN/100ml) | 0 | 0 | 0 |

Sample Analyst:- Padam Singh (Chemist)

Authorized Signatory
SDWQTML, Rishikesh